

7677

I N S E N A T E

May 28, 2014

Introduced by Sens. MARCELLINO, FELDER, HASSELL-THOMPSON, HOYLMAN, PERKINS -- read twice and ordered printed, and when printed to be committed to the Committee on Cities

AN ACT to amend the administrative code of the city of New York, in relation to requiring the installation and maintenance of carbon monoxide detectors in restaurants and other commercial buildings

THE PEOPLE OF THE STATE OF NEW YORK, REPRESENTED IN SENATE AND ASSEMBLY, DO ENACT AS FOLLOWS:

- 1 Section 1. Section 27-981.2 of the administrative code of the city of
2 New York, as added by local law number 7 of the city of New York for the
3 year 2004, is amended to read as follows:
4 S 27-981.2 Carbon monoxide detecting devices; where required. a. Every
5 dwelling unit in a building within occupancy groups J-1, J-2 or J-3
6 where a fossil fuel-burning furnace or boiler is located, and every
7 dwelling unit in a building that is in close proximity to a source of
8 carbon monoxide, as such proximity is established by the rules promul-
9 gated by the commissioner in consultation with the fire department and
10 the department of health and mental hygiene, shall be equipped with an
11 operational carbon monoxide detecting device approved in accordance with
12 the rules promulgated by the commissioner in consultation with the fire
13 department and the department of health and mental hygiene, provided
14 that there shall be installed at least one approved and operational
15 carbon monoxide detecting device within fifteen feet of each room
16 lawfully used for sleeping purposes. Such carbon monoxide detecting
17 device may be combined with a smoke detecting device that complies with
18 the provisions of this title and any applicable rules promulgated there-
19 under.
20 b. In every building classified in occupancy group G or occupancy
21 group H-2, at least one approved and operational carbon monoxide detect-
22 ing device shall be installed in accordance with rules promulgated by
23 the commissioner in consultation with the fire department and the
24 department of health and mental hygiene.
25 c. IN EVERY BUILDING CLASSIFIED IN OCCUPANCY GROUPS F-1, F-3 AND F-4,
26 AT LEAST ONE APPROVED AND OPERATIONAL CARBON MONOXIDE DETECTING DEVICE

EXPLANATION--Matter in *ITALICS* (underscored) is new; matter in brackets
[] is old law to be omitted.

LBD15358-01-4

1 SHALL BE INSTALLED AND MAINTAINED IN ACCORDANCE WITH RULES PROMULGATED
2 BY THE COMMISSIONER IN CONSULTATION WITH THE FIRE DEPARTMENT AND THE
3 DEPARTMENT OF HEALTH AND MENTAL HYGIENE.

4 D. The provisions of this article shall apply retroactively to every
5 building, in accordance with the provisions of subdivision a or subdivi-
6 sion b of this section, irrespective of when such building was
7 constructed or a certificate of occupancy for such building was issued.

8 [d.] E. The provisions of this article may be enforced by the depart-
9 ment, the fire department, the department of health and mental hygiene
10 and the department of housing preservation and development.

11 S 2. This act shall take effect on the one hundred eightieth day after
12 it shall have become a law.