

7524--A

2013-2014 Regular Sessions

I N   A S S E M B L Y

May 23, 2013

---

Introduced by M. of A. BRINDISI, SEPULVEDA, KEARNS, GRAF -- Multi-Sponsored by -- M. of A. JACOBS, SIMANOWITZ -- read once and referred to the Committee on Governmental Operations -- recommitted to the Committee on Governmental Operations in accordance with Assembly Rule 3, sec. 2 -- committee discharged, bill amended, ordered reprinted as amended and recommitted to said committee

AN ACT to amend the executive law, in relation to enacting the "school buildings carbon monoxide act"

THE PEOPLE OF THE STATE OF NEW YORK, REPRESENTED IN SENATE AND ASSEMBLY, DO ENACT AS FOLLOWS:

- 1     Section 1. Section 378 of the executive law is amended by adding a new  
2     subdivision 17 to read as follows:  
3     17. STANDARDS FOR THE INSTALLATION OF OPERABLE CARBON MONOXIDE DETEC-  
4     TORS IN EVERY ELEMENTARY AND SECONDARY SCHOOL BUILDING WITHIN THE STATE  
5     WHEREIN THE USE OF HEATING OR OTHER EQUIPMENT POSES A SUBSTANTIAL RISK  
6     OF EXPOSURE TO CARBON MONOXIDE.  
7     A. SUCH REGULATIONS SHALL PROVIDE THAT: (I) ANY CARBON MONOXIDE  
8     DETECTION EQUIPMENT INSTALLED SHALL BE LISTED BY A NATIONALLY RECOGNIZED  
9     TESTING LABORATORY AS MEETING OR EXCEEDING AMERICAN NATIONAL STANDARDS  
10    INSTITUTE/UNDERWRITERS LABORATORIES (ANSI/UL) STANDARD 2075 OR ANSI/UL  
11    STANDARD 2034; AND (II) CARBON MONOXIDE DETECTION EQUIPMENT SHALL BE  
12    INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND INSTAL-  
13    LATION REQUIREMENTS OF NATIONAL FIRE PROTECTION ASSOCIATION STANDARD  
14    720, 2012 EDITION.  
15    B. FOR ANY SCHOOL BUILDING FOR WHICH A PERMIT FOR NEW OCCUPANCY OR A  
16    PERMIT FOR RENOVATION IS ISSUED ON OR AFTER JANUARY FIRST, TWO THOUSAND  
17    SIXTEEN, SUCH REGULATIONS SHALL (I) PROHIBIT THE INSTALLATION OF ANY  
18    BATTERY-OPERATED CARBON MONOXIDE DETECTION EQUIPMENT OR ANY PLUG-IN  
19    CARBON MONOXIDE WARNING EQUIPMENT THAT HAS A BATTERY AS ITS BACK-UP  
20    POWER SOURCE; AND (II) REQUIRE THAT A SIGNAL FROM A CARBON MONOXIDE  
21    DETECTOR SHALL BE AUTOMATICALLY TRANSMITTED TO AN APPROVED SUPERVISING  
22    STATION OR CONSTANTLY ATTENDED ON-SITE LOCATION.  
23    S 2. This act shall take effect January 1, 2015.

EXPLANATION--Matter in ITALICS (underscored) is new; matter in brackets  
[ ] is old law to be omitted.

LBD10514-03-4