

9772

I N A S S E M B L Y

May 22, 2014

Introduced by M. of A. PAULIN, BRENNAN, ENGLEBRIGHT, ROSENTHAL,
BUCHWALD, GALEF, MOSLEY, OTIS, COOK, GOTTFRIED, JACOBS, LIFTON, STECK
-- Multi-Sponsored by -- M. of A. ARROYO, CAMARA, LUPARDO, THIELE --
read once and referred to the Committee on Corporations, Authorities
and Commissions

AN ACT to amend the public service law, in relation to reporting of
natural gas leaks by gas corporations

THE PEOPLE OF THE STATE OF NEW YORK, REPRESENTED IN SENATE AND ASSEM-
BLY, DO ENACT AS FOLLOWS:

1 Section 1. The public service law is amended by adding a new section
2 67-b to read as follows:
3 S 67-B. NATURAL GAS LEAK REPORTING REQUIREMENTS. 1. THE DEPARTMENT
4 SHALL ESTABLISH A UNIFORM NATURAL GAS LEAK CLASSIFICATION SYSTEM AS SET
5 FORTH IN THIS SECTION.
6 2. ALL LEAKS SHALL BE ASSESSED A CLASS BASED ON THE FOLLOWING SYSTEM:
7 (A) TYPE 1 CLASSIFICATION. (1) A TYPE 1 LEAK IS ONE WHICH, DUE TO ITS
8 LOCATION AND/OR RELATIVE MAGNITUDE, CONSTITUTES A POTENTIALLY HAZARDOUS
9 CONDITION TO THE PUBLIC OR BUILDINGS. IN THE EVENT OF A TYPE 1 LEAK
10 CLASSIFICATION THE FOLLOWING REQUIREMENTS APPLY:
11 (I) THE LEAK SHALL REQUIRE AN IMMEDIATE EFFORT TO PROTECT LIFE AND
12 PROPERTY;
13 (II) CONTINUOUS ACTION SHALL BE THEREAFTER TAKEN UNTIL THE CONDITION
14 IS NO LONGER HAZARDOUS; AND
15 (III) COMPLETION OF REPAIRS SHALL BE SCHEDULED ON A REGULAR DAY-AFT-
16 ER-DAY BASIS, OR THE CONDITION KEPT UNDER DAILY SURVEILLANCE UNTIL THE
17 SOURCE OF THE LEAK HAS BEEN CORRECTED.
18 (2) TYPE 1 LEAKS INCLUDE, BUT ARE NOT LIMITED TO:
19 (I) DAMAGE BY CONTRACTORS OR OUTSIDE SOURCES RESULTING IN LEAKAGE;
20 (II) ANY INDICATION ON A COMBUSTIBLE GAS INDICATOR (CGI) OF NATURAL
21 GAS ENTERING BUILDINGS OR TUNNELS;
22 (III) ANY READING ON A CGI WITHIN FIVE FEET (1.5 METERS) OF A BUILDING
23 WALL;

EXPLANATION--Matter in ITALICS (underscored) is new; matter in brackets
[] is old law to be omitted.

LBD15044-01-4

1 (IV) ANY READING OF FOUR PERCENT OR GREATER GAS-IN-AIR ON A CGI WITHIN
2 MANHOLES, VAULTS OR CATCH BASINS (SAMPLING WILL BE CONDUCTED WITH THE
3 STRUCTURE IN ITS NORMAL CONDITION AS NEARLY AS PHYSICALLY POSSIBLE); OR

4 (V) ANY LEAK WHICH, IN THE JUDGMENT OF THE OPERATING PERSONNEL AT THE
5 SCENE, IS REGARDED AS POTENTIALLY HAZARDOUS.

6 (B) TYPE 2A CLASSIFICATION. (1) A TYPE 2A LEAK DOES NOT PRESENT AN
7 IMMEDIATELY HAZARDOUS CONDITION TO THE PUBLIC OR BUILDINGS, BUT IS OF A
8 NATURE THAT REQUIRES FREQUENT SURVEILLANCE AND SCHEDULED REPAIR. IN THE
9 EVENT OF A TYPE 2A LEAK CLASSIFICATION THE FOLLOWING REQUIREMENTS APPLY:

10 (I) THE LEAK SHALL BE REPAIRED WITHIN A PERIOD NOT TO EXCEED SIX
11 MONTHS; AND

12 (II) THE LEAK SHALL BE MAINTAINED UNDER SURVEILLANCE WITH A FREQUENCY
13 NOT TO EXCEED TWO WEEKS UNTIL REPAIRED.

14 (2) TYPE 2A LEAKS INCLUDE, BUT ARE NOT LIMITED TO:

15 (I) ANY READING OF TEN PERCENT OR GREATER GAS-IN-AIR IN ANY AREA
16 CONTINUOUSLY PAVED FROM THE CURB TO THE BUILDING WALL, WHICH IS MORE
17 THAN FIVE FEET (1.5 METERS) BUT WITHIN THIRTY FEET (9.1 METERS) OF THE
18 BUILDING AND INSIDE THE CURBLINE OR SHOULDER OF THE ROAD;

19 (II) ANY READING, IN AN UNPAVED AREA, OF TWENTY PERCENT OR GREATER
20 GAS-IN-AIR WHICH IS MORE THAN FIVE FEET (1.5 METERS) BUT WITHIN TWENTY
21 FEET (6.1 METERS) OF THE BUILDING AND INSIDE THE CURB OR SHOULDER OF THE
22 ROAD; OR

23 (III) ANY LEAK, OTHER THAN TYPE 1, WHICH, UNDER FROST OR OTHER CONDI-
24 TIONS, IN THE JUDGMENT OF THE OPERATING PERSONNEL AT THE SCENE SHOULD BE
25 CLASSIFIED AS A TYPE 2A.

26 (C) TYPE 2 CLASSIFICATION. (1) A TYPE 2 LEAK DOES NOT PRESENT AN IMME-
27 DIATE HAZARDOUS CONDITION TO THE PUBLIC OR BUILDINGS, BUT IS OF A NATURE
28 REQUIRING SCHEDULED REPAIR. IN THE EVENT OF A TYPE 2 LEAK CLASSIFICATION
29 THE FOLLOWING REQUIREMENTS APPLY:

30 (I) THE LEAK SHALL BE REPAIRED WITHIN A PERIOD NOT TO EXCEED ONE YEAR,
31 EXCEPT THAT LEAKS CLASSIFIED UNDER CLAUSE (V) OF SUBPARAGRAPH TWO OF
32 THIS PARAGRAPH SHALL BE REPAIRED WITHIN SIX MONTHS; AND

33 (II) THE LEAK SHALL BE MAINTAINED UNDER SURVEILLANCE WITH A FREQUENCY
34 NOT TO EXCEED TWO MONTHS, EXCEPT THAT LEAKS CLASSIFIED UNDER CLAUSE (V)
35 OF SUBPARAGRAPH TWO OF THIS PARAGRAPH SHALL BE SURVEILLED EVERY TWO
36 WEEKS.

37 (2) TYPE 2 LEAKS INCLUDE, BUT ARE NOT LIMITED TO:

38 (I) ANY READING LESS THAN TEN PERCENT GAS-IN-AIR BETWEEN THE BUILDING
39 AND THE CURBLINE IN ANY AREA CONTINUOUSLY PAVED WHICH IS MORE THAN FIVE
40 FEET (1.5 METERS) BUT WITHIN THIRTY FEET (9.1 METERS) OF THE BUILDING
41 AND INSIDE THE CURBLINE OR SHOULDER OF THE ROAD; OR

42 (II) ANY READING LESS THAN TWENTY PERCENT GAS-IN-AIR IN ANY UNPAVED
43 AREA WHICH IS MORE THAN FIVE FEET (1.5 METERS) BUT WITHIN TWENTY FEET
44 (6.1 METERS) OF A BUILDING AND INSIDE THE CURBLINE OR SHOULDER OF THE
45 ROAD; OR

46 (III) ANY READING OF THIRTY PERCENT OR GREATER GAS-IN-AIR IN AN
47 UNPAVED AREA WHICH IS MORE THAN TWENTY FEET (6.1 METERS) BUT WITHIN
48 FIFTY FEET (15.2 METERS) OF A BUILDING AND INSIDE THE CURBLINE OR SHOUL-
49 DER OF THE ROAD; OR

50 (IV) ANY READING OF THIRTY PERCENT OR GREATER GAS-IN-AIR IN A PAVED
51 AREA WHICH IS MORE THAN THIRTY FEET (9.1 METERS) BUT WITHIN FIFTY FEET
52 (15.2 METERS) OF A BUILDING AND INSIDE THE CURBLINE OR SHOULDER OF THE
53 ROAD; OR

54 (V) ANY READING ABOVE ONE PERCENT BUT BELOW FOUR PERCENT GAS-IN-AIR,
55 WITHIN MANHOLES, VAULTS OR CATCH BASINS (SAMPLING WILL BE CONDUCTED WITH

1 THE STRUCTURE IN ITS NORMAL CONDITION AS NEARLY AS IS PHYSICALLY POSSI-
2 BLE).

3 (D) TYPE 3 CLASSIFICATION. A TYPE 3 LEAK IS NOT IMMEDIATELY HAZARDOUS
4 AT THE TIME OF DETECTION AND CAN BE REASONABLY EXPECTED TO REMAIN THAT
5 WAY.

6 (1) A TYPE 3 LEAK IS ANY LEAK NOT CLASSIFIED AS TYPE 1, 2A OR 2.

7 (2) TYPE 3 LEAKS SHALL BE REEVALUATED DURING THE NEXT REQUIRED LEAKAGE
8 SURVEY OR ANNUALLY, WHICHEVER IS LESS.

9 3. BEGINNING MARCH FIRST, TWO THOUSAND FIFTEEN, EACH GAS CORPORATION
10 SHALL REPORT ANNUALLY TO THE DEPARTMENT THE LOCATION OF EACH TYPE 1,
11 TYPE 2A, TYPE 2 AND TYPE 3 LEAK EXISTING AS OF THAT DATE CLASSIFIED BY
12 THE CORPORATION, THE DATE EACH TYPE 1, TYPE 2A, TYPE 2 AND TYPE 3 LEAK
13 WAS CLASSIFIED AND THE DATE OF REPAIR PERFORMED ON EACH TYPE 1, TYPE 2A,
14 TYPE 2 AND TYPE 3 LEAK AS PART OF ITS REQUIRED GAS SURVEILLANCE PROGRAM
15 AS REQUIRED UNDER ITS APPROVED OPERATIONS AND MAINTENANCE PROGRAMS. SUCH
16 GAS LEAK INFORMATION SHALL BE MADE AVAILABLE TO ANY MUNICIPAL OR STATE
17 PUBLIC SAFETY OFFICIAL AND ANY MEMBER OF THE LEGISLATURE UPON REQUEST TO
18 THE DEPARTMENT.

19 4. THE DEPARTMENT SHALL PROMULGATE REGULATIONS NECESSARY TO IMPLEMENT
20 THE UNIFORM LEAK CLASSIFICATION STANDARDS AS SPECIFIED IN THIS SECTION,
21 AND SHALL OVERSEE AND MONITOR COMPANY RESPONSE AND REPORTING.

22 5. THE COMMISSION SHALL COMMENCE A PROCEEDING TO INVESTIGATE WHETHER
23 NEW YORK STATE SHOULD REQUIRE THE WINTER SURVEILLANCE AND PATROL OF CAST
24 IRON OR DUCTILE IRON PIPELINES IN THE STATE AND SHALL DETERMINE WHETHER
25 THE PRESENCE OF EXTENDED FROST CAP CONDITIONS MAY RESULT IN ADDITIONAL
26 STRESS ON CAST IRON OR DUCTILE IRON PIPE SEGMENTS, REQUIRING ENHANCED
27 SURVEILLANCE AND PATROL. THE DEPARTMENT IS AUTHORIZED TO ESTABLISH MINI-
28 MUM UNIFORM PROCEDURES FOR CAST IRON AND DUCTILE IRON SURVEILLANCE AND
29 PATROLS. GAS COMPANIES ARE AUTHORIZED TO ESTABLISH PROCEDURES THAT
30 EXCEED ANY MINIMUM STANDARDS AT THEIR DISCRETION.

31 S 2. This act shall take effect immediately.