

STATE OF NEW YORK

1219

2023-2024 Regular Sessions

IN SENATE

January 10, 2023

Introduced by Sens. COMRIE, JACKSON, KAVANAGH, SEPULVEDA, SKOUFIS --
read twice and ordered printed, and when printed to be committed to
the Committee on Housing, Construction and Community Development

AN ACT to amend the executive law, in relation to requiring fire extin-
guishers in every multiple dwelling

The People of the State of New York, represented in Senate and Assem-
bly, do enact as follows:

Section 1. Section 378 of the executive law is amended by adding a new
subdivision 5-e to read as follows:

5-e. Standards for installation of fire extinguishers shall require
installation of such extinguishers in all multiple dwellings at least
one per floor, with the maximum travel distance between extinguishers
not to exceed seventy-five feet. Such fire extinguishers shall be of
such manufacture, design and installation standards as are established
by the council. For purposes of this subdivision, multiple dwelling
means a dwelling which is either rented or leased to be occupied, or is
occupied as the temporary or permanent residence or home of three or
more families living independently of each other, including but not
limited to the following: a tenement, flat house, maisonette apartment,
apartment house, apartment hotel, tourist house, bachelor apartment,
studio apartment, duplex apartment, kitchenette apartment, hotel, lodg-
ing house, rooming house, boarding house, boarding and nursery school,
furnished room house, club, sorority house, fraternity house, college
and school dormitory, convalescent, old age or nursing homes or resi-
dences.

§ 2. This act shall take effect immediately; provided that the
provisions of subdivision 5-e of section 378 of the executive law as
added by section one of this act shall not require compliance by owners
of multiple dwellings before two years after such effective date.

EXPLANATION--Matter in italics (underscored) is new; matter in brackets
[-] is old law to be omitted.

LBD03415-01-3