§ 31. Inside cellar stairs. Every stair leading from a cellar to the floor above in all old multiple dwellings shall be enclosed with fire-retarded partitions and shall be equipped with a fire-retarded self-closing door located as the department may approve.